



CARRIER PIPE DIAMETER	4"	6"	8"	10"	12"
CASING DIAMETER	10"	12"	14"	16"	20"
STEEL CASING THICKNESS	0.25"	0.25"	0.25"	0.25"	0.25"
SPACER BAND WIDTH	8"	8"	8"	8"	8"

NOTES:

- CASING SPACERS SHALL BE "CENTER POSITIONING" TYPE.
- FOR CASING SPACERS SPECS SEE D7-2.10.
- MINIMUM RUNNER WIDTH SHALL BE 2 INCHES.
- RUNNER HEIGHT SHALL BE SIZED TO PROVIDE:
 - MINIMUM 0.75" BETWEEN CARRIER PIPE BELL AND CASING PIPE WALL AT ALL TIMES.
 - MINIMUM 1" CLEARANCE BETWEEN RUNNERS AND TOP OF CASING WALL TO PREVENT JAMMING DURING INSTALLATION.
- STEEL CASING DIAMETERS ARE "OUTSIDE DIAMETER" FOR 16" AND LARGER.
- SPACER BAND WIDTH SHALL BE 12" FOR CARRIER PIPES THAT ARE 36" DIAMETER OR GREATER.
- CASING ANTICORROSIVE COATING THICKNESS - 8 MILLS DFT



City of
Bellevue

STORM AND SURFACE
WATER UTILITY

TITLE

CASING INSTALLATION